

CSI SpA
20021 Bollate - MI - I
Viale Lombardia 20
Tel. +39 02 383301
Fax +39 02 3503940
www.csi-spa.com



Registrazione numero/Registration number

PED/0497/2243/12

CERTIFICATO CE DEL TIPO EC TYPE EXAMINATION CERTIFICATE

Visto il Fascicolo Tecnico/Referring to the Technical File
n° 240/12 del/dated 10/04/2012

si certifica che la Società/we certify that the Company

EMME ANTINCENDIO S.r.l.
Via Del Molino, 40 - 52010 CORSALONE (AR) - ITALY

ha realizzato il seguente Tipo di Insieme in pressione che soddisfa i Requisiti Essenziali di Sicurezza dell'Allegato I
e le procedure del Modulo B, Allegato III, della Direttiva 97/23/CE
*has realized the following Type of pressure Assembly that meets the Essential Safety Requirements of Annex I and the procedures of
Module B, Annex III, of the 97/23/EC Directive*

ESTINTORE PORTATILE A SCHIUMA MODELLO DOLOMITI6 DOLOMITI6 MODEL FOAM PORTABLE FIRE EXTINGUISHER

Carica nominale/Nominal charge Kg 6
TS -30 ÷ +60 °C; PS_{max} 18 barg
Gruppo Fluidi/Fluid Group 2 - Categoria/Category III

12/04/2012

Prima emissione
First issue

//

Ultima emissione
Latest issue

11/04/2022

Scadenza
Expiring