Technical Manual





www.emme-italia.com

Via del Molino, 40 - 52010 Corsalone (AR) - Italy - info@emme-italia.com - Tel. +39.0575.511320 Other branchesin Italy: Milano - Padova - Roma - Palermo - Cagliari - P.IVA/ C.F. 11208251006 - R.E.A. AR-159122

19258 - Lombardia 18241: Wheeled Fire Extinguisher, 25 L Foam



- CYLINDER
 Stainless steel AISI 304,
 powder painting, Red Ral 3000
- EXTINGUISHING AGENT Water based foam.
- PROPELLANT
 Dehumidified air or Nitrogen (N₂).
- VALVE 2"-F, brass body, lever with greer painting Ral 6029.
- USE
 A B fire rating
 (solid materials, flammable liquids)
- BRACKET
 Chassis on wheels, welded at the cylinder, red painting Ral 3000.

Note: image is for illustrative purpose only, the product purchased can have some differences

25 L foam wheeled fire extinguisher, temperature range from +5°C to +60°C, manufactured in accordance to **UNI EN 1866-1 (D.M. 6.3.92)**, approved Marine Equipment Directive **MED 2014/90/EU**, certified according to the directive for pressure equipment PED 2014/68/EU.

Quality Product certification guaranteed by Bureau Veritas Italia.

Suitable for use on fire involving electrical voltages up to 1000 V, at a distance of 1 meter.

APPROVED\CERTIFIED FIRE EXTINGUISHER:













FIRE RATING:





| File name | Type of document | Fire Extinguisher Model | Date | Rele. | Check | Rev. | Pag. |
|------------------------|------------------|-------------------------|------------|-------|-------|------|------|
| 19258_Technical Manual | Technical Manual | 19258 Lombardia 18241 | 01/08/2024 | M.R | | 2 | 1/3 |

REPRODUCTION IS PROHIBITED

19258 - Lombardia 18241: Wheeled Fire Extinguisher, 25 L Foam

INSTALLATION

• USE

The installation and the control and/or recovery operations of fire extinguisher must be performed by qualified technician and in accordance to current regulations on the matter.

MAINTENANCE

The technician will carry out annual inspection for check the internal pressure and after all other steps planned during the fire extinguisher useful life.

Any tampering or operation performed by unqualified technician, void the product warranty. If possible, is recommended to place fire extinguisher in a dry place, protected from atmospheric agents.

For installation, use and maintenance follow as indicated in file: CSP_1_ENG

TECHNICAL SPECIFICATIONS

| FIRE RATING | AIVB |
|------------------------|---|
| EXTINGUISHING AGENT | Water based foam (2 % SC-6 orchidee + 98 % Water) (* Hyper-filtered water with an osmosis process) |
| PROPELLANT | Dehumidified air or Nitrogen (N_2), 15 Bar at 20 $^{\circ}$ C |
| TEMPERATURE RANGE | +5°C / +60°C |
| NOMINAL CHARGE | 25 Liters |
| FULL WEIGHT | ~ 45 Kg |
| DIMENSIONS | Height 930 +/- 10 mm ; Width 425 +/- 10 mm Depth 430 +/- 15 mm |
| DISCHARGE TIME | ~ 27,6 seconds |
| CYLINDER PRESSURE TEST | PT 30 bar |
| CYLINDER VOLUME | 31 L |
| SAFETY DEVICE | Set between 21 and 26 bar |
| CYLINDER MATERIAL | Stainless steel AISI 304 |
| TREATMENT | Outside: Sandblast and powder painting Ral 3000 |


PACKAGING

(Note: the packaging quantities and measurements are indicative and can be subject at changes)

STANDARD

Maximum nr. 6 pieces for pallet

Pallet dimensions 100x120x120(h) cm




TRANSPORT DISPOSAL

Land transport: Exemption for the purposes of ADR disposal 594 Ship Transport: IMDG Code - UN 1044 class 2.2 Fire Extinguishers

| File name | Type of document | Fire Extinguisher Model | Date | Rele. | Check | Rev. | Pag. |
|------------------------|------------------|-------------------------|------------|-------|-------|------|------|
| 19258_Technical Manual | Technical Manual | 19258 Lombardia 18241 | 01/08/2024 | M.R | | 2 | 2/3 |

19258 - Lombardia 18241: Wheeled Fire Extinguisher, 25 L Foam

COMPONENTS AND SPARE PARTS LIST



| NUM. | DESCRIPTION | CODE |
|------|-----------------|--------|
| 1 | Valve 2''-F | 0214RV |
| 1.1 | O-ring valve | 0203 |
| 1.2 | Tamper seal | 0286N |
| 1.3 | Safety pin | 0283R |
| 1.4 | Safety device | 0263R |
| 2 | Pressure gauge | 1576 |
| 3 | Safety pin seal | 0285 |
| 4 | PVC dip tube | 18401 |
| 5 | Cylinder | 18302 |

| NUM. | DESCRIPTION | CODE | |
|------|---|--------|--|
| 6 | Hose | 18421 | |
| 7 | Dispensing nozzle (complete of ball valve with control lever and inox filter for foaming) | 2181-2 | |
| 8 | Wheel + wheel stop (diam. 300mm) | 0124V | |
| 9 | Label | 18366 | |
| | Additive for refill (1 Lt. concentrate - To mix with water, for two refill) | 1470-1 | |

The spare part at number 1, includes already others components from 1.1 to 1.4

| File name | Type of document | Fire Extinguisher Model | Date | Rele. | Check | Rev. | Pag. |
|------------------------|------------------|-------------------------|------------|-------|-------|------|------|
| 19258_Technical Manual | Technical Manual | 19258 Lombardia 18241 | 01/08/2024 | M.R | | 2 | 3/3 |