Technical Manual





Via del Molino, 40 - 52010 Corsalone (AR) - Italy - info@emme-italia.com - Tel. +39.0575.511320 Other branches in Italy : Milano - Padova - Roma - Palermo - Cagliari - P.IVA/ C.F. 11208251006 - R.E.A. AR-159122

S6 SUPER - 22064-1: Portable Fire Extinguisher, 6 L Foam



- CYLINDER Stainless steel, 3 pieces drawing, external powder painting Red Ral 3000.
- EXTINGUISHING AGENT Water-based foam.
- \bullet PROPELLANT Dehumidified air or Nitrogen (N $_2$).
- VALVE CPF M. 30x1.5, brass body, with anti-corrosion treatment.
- USE A B F fire rating (solid materials, flammable liquids, cooking oils).

Note: image is for illustrative purpose only, the product purchased can has some difference

6 L foam fire extinguisher, temperature range from +5°C to +60°C, manufactured in accordance to **UNI EN 3-7 (D.M. 7.1.2005)**, certified according to the directive for pressure equipment PED 2014/68/EU. Manufactured according at productions checks as agreed with **EN 3-10**. Quality Product certification guaranteed by Bureau Veritas Italia.

Suitable for use on fire involving electrical voltages up to 1000 V, at a minimum distance of 1 meter.

APPROVED/CERTIFIED FIRE EXTINGUISHER:							
MTIC	EN 3-10 Inspection Certificate N*55820/21/MM//mj	FIRE RATING :	, <mark>, А</mark>				
D.M. 7 Genrado 2005	* * * * *		L	13	233	75	
File name	Type of document	Fire Extinguisher Model	Date	Rele.	Check	Rev.	Pag.
22064-1_S6 SUPER_Technical manual	Technical manual	S6 SUPER 22064-1	02/10/2024	M.R		2	2/3

S6 SUPER - 22064-1: Portable Fire Extinguisher, 6 L Foam

INSTALLATION

• USE

The installation and the control and/or recovery operations of fire extinguisher must be performed by qualified technician and in accordance to current regulations on the matter.

MAINTENANCE

The technician will carry out annual inspection for check the internal pressure and after all other steps planned during the fire extinguisher useful life.

Any tampering or operation performed by unqualified technician, void the product warranty. If possible, is recommended to place fire extinguisher in a dry place, protected from atmospheric agents. For installation, use and maintenance follow as indicated in file : PSP_1_ENG

TECHNICAL SPECIFICATIONS

FIRE RATING	43 A 233 B 75 F				
EXTINGUISHING AGENT	Foam EWAB1				
PROPELLANT	Dehumidified air or Nitrogen (N $_2$), 15 Bar at 20°C				
TEMPERATURE RANGE	+5°C / +60°C				
NOMINAL CHARGE	6 Liters				
FULL WEIGHT	~ 8,75 Kg				
DIMENSIONS	Height (base - valve) 530 +/- 5 mm Diameter (cylinder) 160 +/- 2 mm				
DISCHARGE TIME	~ 20,9 seconds				
CYLINDER PRESSURE TEST	PT 27 bar				
CYLINDER VOLUME	7,8 Liters				
SAFETY DEVICE	Set between 20 and 24 bar				
CYLINDER MATERIAL	Stainless steel Aisi 304				
TREATMENT	Outside: Sandblast and powder painting Ral 3000				


PACKAGING

(Note: quantities and measurements are indicative and can be subject at changes)

ON REQUEST: SINGLE PACKAGING

- maximum 64 pieces on pallet 100x120
- maximum 48 pieces on pallet 80x120

180 mm 80



STANDARD Maximum nr. 100 pieces for pallet


(44 pieces for box, max 2 boxes for pallet)

(12 pieces. single packaging) Pallet dimensions 100x120x160(h) cm

> TRANSPORT DISPOSAL

Land transport : Exemption for the purposes of ADR disposal 594 Ship Transport : IMDG Code - UN 1044 class 2.2 Fire Extinguishers

File name	Type of document	Fire Extinguisher Model	Date	Rele.	Check	Rev.	Pag.
22064-1_S6 SUPER_Technical manual	Technical manual	S6 SUPER 22064-1	02/10/2024	M.R		2	2/3



COMPONENTS AND SPARE PARTS LIST

NUM.	DESCRIPTION	CODE	NUM.	DESCRIPTION	CODE
1	Valve M. 30x1.5	0212CS	4	Pressure gauge	1576
1.1	O-ring valve (5	PVC dip tube	0154
1.2	Valve stem	0242C	6	6 Cylinder	
1.3	Internal spring of the valve	0251C	7	Hose with dispensing nozzle	0293-2
1.4	Test valve for pressure gauge	1163C	8	Stop hose ring	0301
1.5	Dip tube holder	0253C	9	Label	0081-11
1.6	Safety device	0261C		Foam refill	2054-11
2	Safety pin	0282-1		(6 L. bottle, ready to use)	
3	Safety pin seal	0285			

The spare part at number 1 includes already all others components indicated from 1.1 to 1.6

File name	Type of document	Fire Extinguisher Model	Date	Rele.	Check	Rev.	Pag.
22064-1_S6 SUPER_Technical manual	Technical manual	S6 SUPER 22064-1	02/10/2024	M.R		2	3/3