Technical Manual





Via del Molino, 40 - 52010 Corsalone (AR) - Italy - info@emme-italia.com - Tel. +39.0575.511320 Other branches in Italy : Milano - Padova - Roma - Palermo - Cagliari - P.IVA/ C.F. 11208251006 - R.E.A. AR-159122

22092-61 : Portable Fire Extinguisher, 9 L Foam



Note: image is for illustrative purpose only, the product purchased can has some difference

9 L foam fire extinguisher, temperature range from -30°C to +60°C, manufactured in accordance to **UNI EN 3-7**, approved Marine Equipment Directive **MED 2014/90/EU** certified according to the directive for pressure equipment PED 2014/68/EU. Manufactured according at productions checks as agreed with **EN 3-10**. Quality Product certification guaranteed by Bureau Veritas Italia.

Suitable for use on fire involving electrical voltages up to 1'000 V, at a minimum distance of 1 meter.

APPROVED/CERTIFIED FIRE EXTINGUISHER:

	MPA Dresden EN 3-10 Inspection Certificate N° 55840/21/NMI/nmi	<u>FIRE</u> <u>RATING :</u>	ب ر, 21		183	40	
File name	Type of document	Fire Extinguisher Model	Date	Rele.	Check	Rev.	Pag.
22092-61_Technical manual	technical manual	22092-61	02/05/2024	M.R		1	1/3

22092-61 : Portable Fire Extinguisher, 9 L Foam

INSTALLATION

• <u>USE</u>

performed by qualified technician and in accordance to current regulations on the matter.
The technician will carry out **annual inspection** for check the internal pressure

• MAINTENANCE Th

The technician will carry out **annual inspection** for check the internal pressure and after all other steps planned during the fire extinguisher useful life.

The installation and the control and/or recovery operations of fire extinguisher must be

Any tampering or operation performed by unqualified technician, void the product warranty. I f possible, is recommended to place fire extinguisher in a dry place, protected from atmospheric agents. **For installation, use and maintenance follow as indicated in file : PSP 1 ENG**

TECHNICAL SPECIFICATIONS


FIRE RATING	21 A 183 B 40 F				
EXTINGUISHING AGENT	Foam EW-30 (100 % Premix MG6 -30)				
PROPELLANT	Dehumidified air or Nitrogen (N_2), 15 bar at 20°C				
TEMPERATURE RANGE	-30°C / +60°C				
NOMINAL CHARGE	9 Liter				
FULL WEIGHT	~ 15,15 Kg				
DIMENSIONS	Height (base - valve) 635 +/- 5 mm Diameter (cylinder) 170 +/- 2 mm				
DISCHARGE TIME	~ 34,8 seconds				
VALVE TIGHTENING TORQUE	Minimum 45 Nm, Maximum 68 Nm				
CYLINDER PRESSURE TEST	PT 27 bar				
CYLINDER VOLUME	10,7 L.				
SAFETY DEVICE	Set between 20 and 24 bar				
CYLINDER MATERIAL	Alloy steel				
TREATMENT	Outside: Sandblast and powder painting Ral 3000 - Inside: Plastic coating				

PACKAGING


(Note: quantities and measurements are indicative and can be subject at changes)

STANDARD

ON REQUEST: SINGLE PACKAGING - maximum 40 pieces on pallet 100x120




Maximum nr. 40 pieces for pallet (40 pcs for box, max 1 box for pallet) Pallet dimensions 100x120x80(h) cm



TRANSPORTLand transport : Exemption for the purposes of ADR disposal 594DISPOSALShip Transport : IMDG Code - UN 1044 class 2.2 Fire Extinguishers

File name	Type of document	Fire Extinguisher Model	Date	Rele.	Check	Rev.	Pag.
22092-61_Technical manual	technical manual	22092-61	02/05/2024	M.R		1	2/3

22092-61 : Portable Fire Extinguisher, 9 L Foam



NUM. DESCRIPTION NUM. CODE DESCRIPTION CODE Valve M. 30x1.5 0212CS PVC dip tube 0155-1 1 4 0201C Cylinder 0111-2 1.1 O-ring valve 5 1.2 Valve stem 0242C Hose with dispensing nozzle 0293-6 6 1.3 Internal spring of the valve 0251C 7 Label 0087-61 Test valve for pressure gauge 1.4 1163C 8 Stop-hose band 1907 OPTIONAL 0253C Iron marine bracket red painting 1.5 Dip tube holder 0318-1 1.6 0261C OPTIONAL Wall-mounted bracket for fire Safety device 3036 extinguisher with clip 1.7 Safety pin 0284 Foam refill 2 1576 Pressure gauge 2055-5 (9 L. bottle, ready to use) 3 Safety pin seal (green) 0285

Table 1

The spare part at number 1 includes already all others components indicated from 1.1 to 1.7

File name	Type of document	Fire Extinguisher Model	Date	Rele.	Check	Rev.	Pag.
22092-61_Technical manual	technical manual	22092-61	02/05/2024	M.R		0	3/3